



# RZN 4404-M

Troubleshooting Guide (1 of 2)




## Breakglass display indications

● + ○ + ○	<b>Solid green</b> - System healthy, no faults.
● + ● + ○	<b>Solid green, flashing yellow</b> - System healthy, no fault. Inbuilt service timer expired. Contact Dyer's service & maintenance department.
○ + ● + ○	<b>Flashing yellow</b> - System fault. See panel display indications below.
○ + ○ + ●	<b>Solid red</b> - System in fire.



## Panel display indications


<b>D6</b> Control	• System healthy, no faults.
<b>D7/D10</b> Line	<ul style="list-style-type: none"> <li>Indicates an issue between the control panel and control elements (fire alarm interface, smoke detector or breakglass).</li> <li>Each control element requires a single 10kΩ end of line resistor. See above detail.</li> <li>If no fire alarm interface or smoke detector in system, leave 10kΩ end of line resistor in RM terminals "R" &amp; "-".</li> <li>Check external signal fuse has not blown.</li> </ul>
<b>D8/D11</b> Alarm	• System in fire.
<b>D9/D12</b> Group	<ul style="list-style-type: none"> <li>Issue between the control panel and the drive(s). Ensure EM 47 K drive group end of line is connected as indicated above.</li> <li>Check 3.15 Amp fuse has not blown.</li> </ul>
<b>D86</b> Battery	• Incorrect connection of the batteries or 3.15 Amp fuse blown.





## RZN 4404-M

Troubleshooting Guide (2 of 2)



### **Operational faults**

#### **Fire alarm interface:**

- Confirm signal from interface is normally open volt free.
- 1k $\Omega$  triggering resistor installed as detailed on previous page.
- 10k $\Omega$  end of line resistor installed as detailed on previous page

#### **Smoke detector:**

- Ensure the 10k $\Omega$  end of line resistor is installed as detailed on previous page.
- Turn smoke detector head clockwise until a click is heard and a physical connection is made between head and base.

#### **Breakglass:**

- 10k $\Omega$  end of line resistor installed and connections as detailed on previous page.
- Confirm the breakglass terminal connector is firmly secured onto the PCB.
- Check external signal fuse is present and has not blown.

#### **Drive:**

- Check MOT terminal connections in the control panel and local connection point.
- Test power supply from terminals A and B in control panel, minimum of 24v DC should be present on operation (fire).
- If voltage is present on operation and connections are correct, the issue is with the drive(s) and not the controls, see drive information for assistance.
- If no voltage is present on operation, check 3.15 Amp fuse is present and has not blown.

#### **DIP-Switches:**

- For operational set-up (including one-touch reset of system) see information on control panel data sheet.